



DET NORSKE VERITAS CERTIFICATION LICENCE

Licensee:
Teknisk Industrivern AS
Postboks 82 Laksevåg
N-5847 Bergen

License No.: **130-01-0**
DNV file No. : **345.2-2**
This licence include(s) **3** appendix/ces.

Registered number of business enterprise(s):
934518160

This licence is valid for the portable fire extinguishers given in the appendix/ces

Certified products mentioned in this licence are to be marked with DNV logo and the identification no.

Contact person:
Jarle Samdal



Telephone: Telefax:
55944130 **55944131**

Product group, type and identification No :
See appendix.

Name and address of manufacturer:
Yuyao Orientx Fire Safety Equipment
Wucheyan Town Yuyao Ningbo
PC 315466 V.R.China

Valid standard:
NS-EN-3

For Det Norske Veritas AS


Kristin Urdahl
Head of Section
Fire Safety



Place and date:
Høvik, Norway 13 July 2004

The licence is valid until:
31 December 2009

Det Norske Veritas AS hereby give the Owner of this licence the right to use the DNV mark on or in connection with the products that fulfils the requirements given in the referred standard/Instruction.

The certification licence is valid provided that the Owner of the licence follows the valid Standard for Certification No. 2.19 "Certification of portable fire extinguishers for the Norwegian Market".

The licensee shall have the responsibility to indemnify and hold harmless DNV against any claim for compensation caused by or related to the product manufactured and/or sold by the licensee, including, but not limited to, defects related to the product itself.



If any person suffers loss or damage which is proved to have caused by any negligent act or omission of Det Norske Veritas, then Det Norske Veritas shall pay compensation to such person for this proved direct loss or damage. However, the compensation shall not exceed an amount equal to ten times the fee charged for the service in question, provided that maximum compensation shall never exceed USD 2 million. In this provision "Det Norske Veritas" shall mean the Foundation Det Norske Veritas as well as all the subsidiaries, directors, officers, employees, agents and any other acting on behalf of Det Norske Veritas.

The certification licence is valid for one calendar year, subject to three months notice of termination by both the licensee and DNV. Where no notice of termination has been given, the licence shall automatically be extended on a yearly basis.

A certification licence is not transferable.

Handwritten initials

Appendix No. 1

Product name:	OREX PG1
Identity no.:	130-001
Fire classification:	5A, 34B
Temperature range:	-30°C TO + 60°C
Extinguishing medium:	Powder, SYNT ABC
Charge volume:	1 KG
Description:	Manufactured according to the following main drawings: MFZL1EN-O Rev.1 , Y001021B-00 Rev. 1, MFZL1E-4 Rev. 1, MFZL1E-4-1 Rev. 1, MFZL1E-4-2, Rev. 1, SA-11B-00 Rev.1.
Type testing:	Test reports No. P401250-C dated 2004-06-04 from SP Sweden, No. BT-73/02 dated 2002-12-10 from Institut der Feuerwehr, Münster, Germany, No. 107907 dated 2002-01-18 and No. 105363 dated 2001-09-05 from TÜV, München, Germany.
Marking:	  Marking according to Standard for Certification No. 2.19 items 4 and 6. Identification No 130-001 to be placed below the DNV mark.
Notes:	In order to maintain the validity of the licence the manufacturer is obliged to inform DNV about any changes in the information given in this Appendix.

Place and date

Høvik, Norway 10 November
2004



Surveyor




KML

Appendix No. 2

Product name:	OREX PG2
Identity no.:	130-002
Fire classification:	13A, 70B
Temperature range:	-30°C TO + 60°C
Extinguishing medium:	Powder, SYNT ABC
Charge volume:	2 KG
Description:	Manufactured according to the following main drawings: MFZL2EN-O Rev.1 , Y001021C-00 Rev. 1, MFZL2E-4 Rev. 1, MFZL2E-4-1 Rev. 1, MFZL2E-4-2, Rev. 1, SA-11B-00 Rev.1.
Type testing:	Test reports No. P401250-B dated 2004-06-04 from SP Sweden, No. BT-73/02 dated 2002-12-10 from Institut der Feuerwehr, Münster, Germany, No. 107907 dated 2002-01-18 and No. 105363 dated 2001-09-05 from TÜV, München, Germany. No. F416505 dated 13 October 2004 from SP, Sweden.
Marking:	  Marking according to Standard for Certification No. 2.19 items 4 and 6. Identification No 130-002 to be placed below the DNV mark.
Notes:	In order to maintain the validity of the licence the manufacturer is obliged to inform DNV about any changes in the information given in this Appendix.

Place and date



Høvik, Norway 10 November
2004



Surveyor


KML

Appendix No. 3

Product name:	OREX PG6
Identity no.:	130-003
Fire classification:	34A, 183B
Temperature range:	-30°C TO + 60°C
Extinguishing medium:	Powder, SYNT ABC
Charge volume:	6 KG
Description:	Manufactured according to the following main drawings: MFZL6EN-O Rev.1, MFZL6E-4 Rev. 1, MFZL6E-4-2, Page 1 and 2, Rev. 1, MFZL6E-3 Rev. 1, A-11B-00 Rev.1.
Type testing:	Test reports No. P401250-A dated 2004-06-04 from SP Sweden, No. BT-73/02 dated 2002-12-10 from Institut der Feuerwehr, Münster, Germany, No. 107907 dated 2002-01-18 and No. 105363 dated 2001-09-05 and No. 105367 2001-10-15 from TÜV, München, Germany. No. F416505 dated 13 October 2004 from SP, Sweden
Marking:	  Marking according to Standard for Certification No. 2.19 items 4 and 6. Identification No 130-003 to be placed below the DNV mark.
Notes:	In order to maintain the validity of the licence the manufacturer is obliged to inform DNV about any changes in the information given in this Appendix.

Place and date

Høvik, Norway 10 November
2004



Surveyor



4772