



Licensee No. : 130-01  
DNV File No.: 345.2-2

Appendix No. 5

<b>Product name:</b>	OREX S6
<b>Identity no.:</b>	130-005
<b>Fire classification:</b>	21A, 144B
<b>Temperature range:</b>	0°C TO + 60°C
<b>Extinguishing medium:</b>	Water + 3% ENT A3F3 Foam
<b>Charge volume:</b>	6 L
<b>Description:</b>	Manufactured according to the following main drawings: MJPZ6EN-0, Rev. 1 Fire Extinguisher MJPZ6E5a /5a01 Pressure vessel
<b>Type testing:</b>	Test reports No. P 502295-A dated 2006-01-16 from SP Sweden, No. 105367 dated 2001-10-15 from TÜV, München, Germany. No. F614453 dated 25 September 2006 from SP (Dielectric test) No. 2010-F-3260/BS 01 dated 8 October 2010 from MPA Dresden, Germany (EN 3-7 for 21A)
<b>Marking:</b>	 Marking according to Standard for Certification No. 2.19 items 4 and 6. Identification No 130-005 to be placed below the DNV mark.
<b>Notes:</b>	In order to maintain the validity of the licence the manufacturer is obliged to inform DNV about any changes in the information given in this Appendix.

*Place and date*

Høvik, Norway 7 January 2011

  
\_\_\_\_\_  
Rolf Emilsen  
Surveyor